

# HNEI Grid Integration

ERM Calibration and Resource Adequacy | October 13, 2021



T E L O S E N E R G Y

Funding provided by Energy Systems Development Fund and Office of Naval Research

# Why does the planning reserve margin need to change?

Traditional capacity expansion planning used a **planning reserve margin**, that required some amount of surplus capacity above **peak load** to cover uncertainty in generator outages and load variability


## But...

- Reliability risk is shifting outside of single peak load hour (all hours matter)
- Availability of variable renewable resources fluctuate on an hourly basis
- Correlation among resource availability
- Storage and demand resources have energy limitations

More info: Gord Stephen, "[Getting Past Capacity Credits, Better Deterministic Adequacy Analysis via Energy Reserve Margins](#)," NERC Probabilistic Assessment Forum, Oct 6, 2021.

FIGURE 3

Two Driving Factors That Require New Approaches to Resource Adequacy



Source: Energy Systems Integration Group.

More info: Energy Systems Integration Group, "[Redefining Resource Adequacy for Modern Power Systems](#)," Aug 2021.

# Deterministic Analysis (ERM) vs. Probabilistic Analysis

## Deterministic Analysis (ERM)

Used directly as an input capacity expansion models (i.e. RESOLVE)

- Reliability screening metric
- Metrics: planning reserve margin (peak load) or energy reserve margin (based on all hours)
- Requires capacity value (accreditation) to count variable renewables (HDC) and energy storage
- Evaluated on a single weather year for wind, solar, and load
- Does not explicitly model forced outages of thermal fleet (this is why the reserve margin is required)


## Probabilistic Analysis (LOLP)

Used to measure the reliability resulting from a capacity expansion model

- Detailed resource adequacy assessment
- Metrics: loss of load probability (LOLP), LOLE, LOLH, and expected unserved energy (EUE)
- Used to develop inputs into deterministic analysis (reserve margin and capacity accreditation)
- Many chronological weather years for solar, wind, and load variability
- Randomly draws hundreds of different generator outage possibilities

**A robust modeling process should include *both* deterministic and probabilistic analysis**

# HECO Energy Reserve Margin Overview



**Thermal Capacity:** assumes full nameplate capacity for fossil-fuel units.

**Solar HDC:** Hourly dependable Capacity (HDC) discounts solar capacity value (assumes  $2\sigma$  of hourly output across multiple years of data). Includes the same hour of the day before, day of, day after.

**Wind HDC:** same as solar, but assumes  $1\sigma$  of hourly output

**Storage & DR:** Scheduled based on energy limitations

**ERM:** 30% for Oahu, Maui, Big Island required to cover **forced outages** and **load uncertainty**

**Q: How was the minimum ERM determined?**

← TAP recommended additional analysis here (focus of today)

# HNEI & Telos Approach to Stochastic Analysis of Resource Adequacy to Address Interannual Resource Variability



- Historical inter-annual solar variability applied to future grid
- Uncertainty and timing of generator outages considered
- Each analysis evaluates capacity shortage across 2.5 million hours of possible operation.
- Methodology allows detailed month-by-month characterization of LOL events
- PLEXOS is the modeling tool for stochastic simulations

Example of Loss of Load Hours by Sample  
Outage Draws

Solar Year	1	2	3	4	5	6	7	8	9	10	...	N
1998	0	0	10	3	0	0	2	0	3	6	0	0
1999	2	0	9	0	3	0	0	0	0	0	3	0
2000	0	0	0	0	0	0	0	2	0	0	6	0
2001	0	0	0	2	0	0	0	0	0	0	0	0
2002	0	0	0	0	0	0	0	6	0	0	0	0
2003	0	0	1	0	0	0	0	0	0	0	0	1
2004	0	2	0	0	0	1	0	0	0	0	0	0
2005	0	0	0	4	0	0	0	1	0	0	0	0
2006	0	0	0	0	0	0	0	0	0	0	3	0
2007	0	3	0	0	0	2	0	0	0	0	0	0
2008	3	0	0	0	0	0	0	5	0	0	0	0
2009	0	0	2	0	1	0	0	1	0	0	3	0
2010	0	0	0	0	0	0	0	0	0	0	0	0
2011	11	0	2	0	0	0	0	0	1	0	3	0
2012	0	3	0	0	0	0	0	0	0	0	0	0
2013	2	0	3	3	0	2	0	0	0	0	0	7
2014	0	0	10	0	0	0	0	0	0	0	0	0
2015	1	0	0	0	3	0	8	0	0	0	0	0
2016	0	1	0	2	0	0	0	0	1	0	0	0
2017	0	0	0	0	0	0	1	1	0	0	0	0
2018	0	10	0	0	0	0	0	0	0	0	0	1

Average across 504 simulations yields LOLE for one specified grid conditions  
~4.4 million hours of simulation per case

# ERM Test Cases, Key Inputs & Assumptions

HECO ran RESOLVE cases at various levels of thermal retirements and ERM levels...  
 ... resulting portfolios were input into probabilistic analysis

Oahu	Energy Reserve Margin				
	0%	10%	20%	30%	40%
Waiau 3					
Waiau 4					
Waiau 5					
Waiau 6					
Waiau 7					
Waiau 8					
Kahe 1					
Kahe 2					
Kahe 5					
Kahe 6					
BESS 140MW					
LM6000 1					
LM6000 2					
LM6000 3					
<b>Net Capacity Change after Stage 2</b>	<b>-496</b>	<b>-395</b>	<b>-309</b>	<b>-168</b>	<b>-76</b>

Retirements

Additions



5 scenarios evaluated in more detailed probabilistic model (next slides)



Maui	Energy Reserve Margin				
	0%	10%	20%	30%	40%
Kahului 1-4					
Maalaea 4-9					
Maalaea 10					
Maalaea 11					
Maalaea 12					
Maalaea 13					
<b>Net Capacity Change</b>	<b>-115</b>	<b>-103</b>	<b>-90</b>	<b>-78</b>	<b>-66</b>

### Other assumptions

- ✓ AES and Kahului Retirements
- ✓ Full Stage 1 & 2 deployment
- ✓ CBRE and DR program installations
- ✓ 2030 IGP DER forecast
- ✓ 2030 IGP Load Forecast

# Oahu Preliminary Results



Evaluating the relationship between ERM and probabilistic model results (LOLE), preliminary (N = 252)



**30% seems to be there, but potentially very sensitive to portfolio resources  
need to do the more analysis on future resources mixes to determine if it is appropriate moving forward?**

# Maui Preliminary Results

Evaluating the relationship between ERM and probabilistic model results (LOLE), preliminary results (N = 220)



30% ERM portfolio ~0.09 days of shortfall per year, in the range of reasonable reliability



# Observations and Next Steps

- Based on initial test cases, a 30% ERM proposed by HECO shows a reasonable level of reliability - for the current resource mix - when evaluated with more detailed probabilistic assessment
- The difference between the ERM and probabilistic analysis when OSW is added indicates more calibration may be necessary for future resources
- Grid planning should include *both* a simplified ERM deterministic metric and more detailed probabilistic metrics for resulting portfolios
- **Next steps:**
  - Additional evaluation of HDC values for variable renewable resources is warranted
  - More analysis around wind resources and 20-years of wind data for both LBW and OSW