

Current Generation Mix

◆ Not Flexible

- ◆ 12 HECO Steam Units
- ◆ AES Coal Fired Unit
- ◆ Characteristics
 - ◆ 3 to 24 hours to start
 - ◆ 2.5 to 5 MW/Min Ramp
 - ◆ Poor turndown*
 - ◆ Corrosion and other concerns with long term shutdown

◆ Flexible

- ◆ SGS (6 RICE)
 - ◆ Fuel Flexible
 - ◆ Offline to Full load: 6 minutes
- ◆ HECO Combustion Turbines (CTs)
 - ◆ 20 to 30 minute start time
 - ◆ Ramp 4 to 13 MW/Min
- ◆ KPLP

* HECO has made significant progress in developing turndown processes at existing steam units but long term reliability and maintenance cost issues exist. Restoration from low load operation takes ~ 2 hours



Hawaiian Electric Generating Fleet Age

- ◆ Steam Unit Age
 - ◆ 55 years average age
 - ◆ 9 of 12 units over 50
 - ◆ 1 of 12 less than 40
- ◆ Peaking Units
 - ◆ 2 of 4 approaching 50 years old
- ◆ AES Retire: 2022
- ◆ KPLP approaching 30 years


- ◆ Note: from HECO 2020 TY Rate case. Age based on unit age in 2020

| Unit | Type/Fuel | Capability | | Year Commercial | Age |
|---------------------------------|--------------------------|------------|--------------|--------------------|-------|
| | | Gross MW | Net MW | | |
| Kahe 1 | Reheat Steam/LSFO | 86 | 82.2 | 1963 | 57 |
| Kahe 2 | Reheat Steam/LSFO | 86 | 82.2 | 1964 | 56 |
| Kahe 3 | Reheat Steam/LSFO | 90 | 86.2 | 1970 | 50 |
| Kahe 4 | Reheat Steam/LSFO | 89 | 85.3 | 1972 | 48 |
| Kahe 5 | Reheat Steam/LSFO | 142 | 134.6 | 1974 | 46 |
| Kahe 6 | Reheat Steam/LSFO | 142 | 133.8 | 1981 | 39 |
| Waiau 7 | Reheat Steam/LSFO | 87 | 83.3 | 1966 | 54 |
| Waiau 8 | Reheat Steam/LSFO | 90 | 86.2 | 1968 | 52 |
| Total Baseload/Load | | 812 | 773.8 | Average Age | 50.25 |
| Waiau 3 | Non-Rehate Steam/LSFO | 49 | 47 | 1947 | 73 |
| Waiau 4 | Non-Rehate Steam/LSFO | 49 | 46.5 | 1950 | 70 |
| Waiau 5 | Non-Rehate Steam/LSFO | 57 | 54.5 | 1959 | 61 |
| Waiau 6 | Non-Rehate Steam/LSFO | 56 | 53.7 | 1961 | 59 |
| Total Cycling Capability | | 211 | 201.7 | Average Age | 65.75 |
| Waiau 9 | Simple Cycle CT/ Diesel | 53 | 52.9 | 1973 | 47 |
| Waiau 10 | Simple Cycle CT / Diesel | 50 | 49.9 | 1973 | 47 |
| CIP CT-1 | Simple Cycle CT / Diesel | 113 | 112.2 | 2009 | 11 |
| SGS | RICE/Biodiesel | 50 | 50 | 2018 | 2 |
| Total Peaking Capability | | 216 | | | 26.75 |



Hawaiian Electric Generating Fleet Age


Comparison: US Electric Generation % Capacity by Age v. HECO Generator Capacity by Age (Traditional Generators, Non-Hydro, Non-Nuclear)



◆ Note: Does not include firm IPPs



EPRI: Plant Age v. EFOR



◆ 2000 – 2017 US Coal Fleet Operation

- Baseload Operation (<10 starts per year)
 - EFOR 5-6%
- Extended Shutdown
 - EFOR ~ 7%
- Load Following (SF >70, CF <60)
 - EFOR ~7%
 - HECO RH Unit Operation
- Min Load Operation
 - EFOR >7%
- On/Off Cycling
 - EFOR 11-12%



Cost with Long Term Operation


- ◆ Increased Forced Outages
- ◆ Increased O&M
- ◆ Increased Capital Expenditures between now and 2045
 - ◆ \$980M (in 2016 dollars)
- ◆ Safety Risk:
 - ◆ Failure of High Temp/High Pressure Components
 - ◆ Failure of Rotating Equipment



Cost with Long Term Operation

Major Challenges: 0 – 30% MCR

| Flexibility Challenges: <i>Boiler, Turbine, BOP, Environmental</i> | Cycling On/Off | Turn Down | Fast Ramping | Load Cycling |
|--|----------------|-----------|--------------|--------------|
| Equipment Turndown | | | | |
| Burners/Combustion Stability | | | | |
| Boiler Circulation | | | | |
| Pressure Part Damage | | | | |
| Fans/Motor Reliability | | | | |
| Ramp Rate | | | | |
| Steam Temperature Control | | | | |
| Air Heater Issues | | | | |
| Environmental Control Systems | | | | |
| Turbine Thermal Stresses | | | | |
| Condenser Issues | | | | |
| Water/Steam Cycle Chemistry | | | | |
| FW Pumps & Motors | | | | |



- ◆ EPRI: General rule of thumb for fleet planning: On average over the life of assets, EFOR will increase 0.006% per lifetime start for subcritical drum units.
- ◆ → W5/6 currently have over 250 starts per year. RH units 3-5 but expecting hundreds.



Summary

- ◆ Existing Firm Generation
 - ◆ Currently necessary
 - ◆ Currently aging and challenged
 - ◆ Expect increased O&M and Capex with current operating profiles
 - ◆ Not well suited for future operating mission profiles
- ◆ Generating units will continue to be necessary
- ◆ Desired Generation Characteristics
 - ◆ Quick Starting
 - ◆ Low or no minimum run time
 - ◆ Turndown capability
 - ◆ Quick ramping



IGP Order No. 36725

Providing Guidance



Hawaiian Electric
Maui Electric
Hawai'i Electric Light

IGP Order No. 36725 Providing Guidance

Independent Evaluation

- ◆ Commission sees value in third party technical expertise for IGP decision-making
- ◆ Expects the Companies to use the Technical Advisory Panel to provide independent review of each Review Point filing

Review Points

- ◆ Filings should specify how efforts were coordinated with related dockets, describe how stakeholder feedback has been incorporated into the IGP process, and update timelines to reflect any major changes

Timelines

- ◆ Understandable that the first iteration of IGP may take longer than planned
- ◆ Companies should allow themselves enough time to complete the necessary steps
- ◆ Companies should develop and update timelines as needed and consider presenting at WG, SC, and TAP meetings
 - ◆ At minimum each review point filing should contain an updated timeline
- ◆ Notify the commission if additional clarity on timelines is required for any docket upon which IGP depends



Next Steps

- ◆ Work towards finalizing the IGP Solution Sourcing Diagram to begin development of individual process step details
- ◆ Discuss the set of grid service needs and their definitions that will be identified by the planning models in the first IGP cycle

