



**Hawaiian  
Electric**

# 2021 System Stability Study IGP TAP Review

Transmission Planning Department  
January 21, 2022


# Agenda

---


- ◆ Addressing TAP feedback from 2021 Dec meeting
- ◆ Summary of “System Scan” PSCAD study results for major islands
- ◆ Discussions



# Addressing TAP Feedback from 2021 Dec Meeting



# Dispatch Scenarios




# 2021 System Stability Study

---

## ◆ Study objectives:

- Address system level near term needs (five/Six years) since commission of Stage 2 IPP projects.
- Preparation for IGP-System Security Study.



# Studied Dispatch Scenarios – O`ahu

## Thermal Generation

---

- Statistics of thermal generation (MW) in 2028 between 11-13 hr and 18-20 hr.

### Thermal generation Daytime Scenario


- High inverter based Renewable
- Median inverter based Renewable
- Low inverter based Renewable

### Thermal generation evening scenario

- High inverter based renewable
- Low inverter based renewable




# Studied Dispatch Scenarios – O`ahu System Physical Inertia (MVA\*s)



# Studied Dispatch Scenarios – O`ahu Renewable Generation

Y2028 Resource Planning



- Evening Scenarios
- ▲ Daytime Scenarios





# Studied Dispatch Scenarios – O`ahu

## Studied Dispatches

---

2028 Cases	Synchronous Machines (MW)				Centralized Renewable IPPs-GFL		Centralized Renewable IPPs-GFM		DER		System Demand (MW)
	Generation (MW)	Inertia (MVA*s)	Up-Reg (MW)	Total MVA	Generation (MW)	Total MW	Generation (MW)	Total MW	Generation (MW)	Installed Capacity (MW)	
DP-HD-HW											
DP-HD-LW											
DP-MaxD-LW-S											
DP-LD-HW											
DP-LD-LW											
EP-HD-HW											
EP-HD-LW											
EP-LD-LW											
EP-LD-LW											



# Studied Dispatch Scenarios – Maui Island Thermal Generation

---

- Statistics of thermal generation (MW) in 2028 between 11-13 hr and 18-20 hr.

Thermal generation Daytime Scenario


- High Renewable
- Low Renewable

Thermal generation evening scenario

- High renewable
- Low renewable




# Studied Dispatch Scenarios – Maui Island System Physical Inertia (MVA\*s)



# Studied Dispatch Scenarios – Maui Island Renewable Generation

## Y2028 Resource Planning



- Evening Scenarios
- ▲ Daytime Scenarios



# Studied Dispatch Scenarios – Maui Island

## Studied Dispatches

2028 Cases	Synchronous Machines (MW)				Centralized Renewable IPPs-GFL		Centralized Renewable IPPs-GFM		DER		System Demand (MW)
	Generation (MW)	Inertia* (MVA*s)	Up-Reg (MW)	Total MVA*	Generation (MW)	Total MW	Generation (MW)	Total MW	Generation (MW)	Installed Capacity (MW)	
DP-HD-HW											
DP-HD-LW											
DP-LD-HW											
DP-LD-LW											
EP-HW											
EP-LW											
EP-LD-LW											

\*Including inertia and MVA from two units of syn. condenser.



# Studied Dispatch Scenarios – Hawai`i Island Thermal Generation

---

- Statistics of thermal generation (MW) in 2029 between 10-13 hr and 17-19 hr.

Thermal generation Daytime Scenario


- Base
- Sensitivity

Thermal generation evening scenario

- Base
- Sensitivity




# Studied Dispatch Scenarios – Hawai`i Island System Physical Inertia (MVA\*s)



# Studied Dispatch Scenarios – Hawai`i Island Renewable Generation

Y2028 Resource Planning



- Evening Scenarios- Base case
- ▲ Daytime Scenarios- Base case
- Evening Scenarios-Sensitivity case
- ▲ Daytime Scenarios-Sensitivity case





# Studied Dispatch Scenarios – Hawai`i Island

## Studied Dispatches

### Base Case

2029 Cases	Synchronous Machines (MW)				Centralized Renewable IPPs-GFL		Centralized Renewable IPPs-GFM		DER		System Demand (MW)
	Generation (MW)	Inertia* (MVA*s)	Up-Reg (MW)	Total MVA*	Generation (MW)	Total MW	Generation (MW)	Total MW	Generation (MW)	Installed Capacity (MW)	
DP-HD-HW											
DP-HD-LW											
DP-LD-HW											
EP-HD-HW											
EP-HD-LW											
EP-LD-LW											



# Studied Dispatch Scenarios – Hawai`i Island

## Studied Dispatches


---

### Sensitivity Case

2029 Cases	Synchronous Machines (MW)				Centralized Renewable IPPs-GFL		Centralized Renewable IPPs-GFM		DER		System Demand (MW)
	Generation (MW)	Inertia* (MVA*s)	Up-Reg (MW)	Total MVA*	Generation (MW)	Total MW	Generation (MW)	Total MW	Generation (MW)	Installed Capacity (MW)	
DP-HD-HW											
DP-HD-LW											
DP-LD-HW											
EP-HD-HW											
EP-HD-LW											
EP-LD-LW											



# DER Modeling



# DER Modeling

---

- ◆ What characteristics does Hawaiian Electric think are important to be understood about DER?
  - From transmission planning perspective:
    - Control topology
    - Momentary cessation (entering into MC and recovery from MC)
    - Frequency response
    - ROCOF response



# DER Modeling

---

- ◆ How Hawaiian Electric has segmented the DER fleet?
  - Grouping DER per ride-through requirements in interconnection technical requirements
    - P1 – Legacy DER (IEEE 1547-2003)
    - P2 – Reprogrammed DER (IEEE 1547-2003, with extended UF ride-through)
    - P3 – Post-2016 DER (comply with Rule 14 2015 October revision)
    - P4 – IEEE 1547-2018 certified DER



# DER Modeling

---

- ◆ How Hawaiian Electric has characterized the behavior of each segment
  - Control – generic GFL control
  - Ride-through and tripping – Hawaiian Electric characterizes each group of DER per technical standard minimum requirements and test results.
- ◆ What approaches Hawaiian Electric thinks are reasonable & manageable for reducing the remaining uncertainty in DER behavior.
  - Using study to inform and improve interconnection technical standard
  - Using interconnection technical standard to inform DER modeling.



# DER Modeling

## DER Momentary Cessation (MC)




Figure 1: Illustration of Momentary Cessation

Credit: NERC

DER Type	UV Block Limit (V <sub>mc</sub> , PU)	UV Unblock Limit (V <sub>mc</sub> , PU)	Recovery Delay* (Δt <sub>sr</sub> , s)	Recovery Ramp Rate (during Δt <sub>rr</sub> , pu/s)
P1	0.45	0.45	0.033	2.2
P2	0.45	0.45	0.033	2.2
P3	0.5	0.5	0.033	2.2

\*“Recovery Delay” means from the point voltage recovers above the UV unblock limit to when DER inverter active current starts to recover.

# Negative Sequence Voltage Resulting from DER Tripping on One Phase





# 0% Syn Generation Scenario



# 0% Syn Generation Scenario

---

- ◆ No 0% Syn. Generation scenario per 2028/2029 resource planning for major islands.
- ◆ 0% Syn. Generation scenarios are studied for Molokai and Lanai.
- ◆ Per resource planning, it is unlikely to have 0% Syn. Generation scenario for O`ahu island; but it is worth to try N-1-1 for Hawai`i and Maui island to create 0% Syn. Generation scenarios for the study.



# “System Scan” with Starting Point Assumptions

## PSCAD Study Results



# PSCAD Study Scenarios

## # of PSCAD Simulation Cases

---

Planning Event	Description	O`ahu	Maui Island	Hawai`i
P1	3PH Fault w/ Loss of Transmission Line (w/ Reclosing)	11	8	1
	3PH Fault w/ Loss of Generator	0	0	0
	Loss of Generator (No Fault)	0	0	0
P2	3PH Bus Fault	5	0	2
P3	Select Cases (Loss of generator with system adjustments) - P1 Analysis	0	0	1
P4	SLG Fault with Breaker Failure (Loss of Multiple Elements)	13	5	9
P5	3PH Fault w/ Delayed Clearing (Loss of Non-Redundant Component of Protection System)	15/16	21	19



\*In Progress

# PSCAD Study Scenarios

## # of PSCAD Simulation Cases – O`ahu

Planning Event	Description	DP-HD-HW	DP-HD-LW	DP-MaxD-LW-S	DP-LD-LW	DP-LD-HW	EP-HD-HW	EP-HD-LW	EP-LD-LW
P1	3PH Fault w/ Loss of Transmission Line (w/ Reclosing)	0	0	10	0	0	0	0	1
	3PH Fault w/ Loss of Generator	0	0	0	0	0	0	0	0
	Loss of Generator (No Fault)	0	0	0	0	0	0	0	0
P2	3PH Bus Fault	0	0	6	0	0	0	0	0
P3	Select Cases (Loss of generator with system adjustments) - P1 Analysis	0	0	0	0	0	0	0	0
P4	SLG Fault with Breaker Failure (Loss of Multiple Elements)	0	0	13	0	0	0	0	0
P5	3PH Fault w/ Delayed Clearing (Loss of Non-Redundant Component of Protection System)	0	15/16	0	0	0	0	0	0



\*In Progress

# PSCAD Study Scenarios

## # of PSCAD Simulation Cases – Maui Island

Planning Event	Description	DP-HD-HW	DP-HD-LW	DP-LD-LW	DP-LD-HW	EP-HW	EP-LW	EP-LD-LW
P1	3PH Fault w/ Loss of Transmission Line (w/ Reclosing)	2	2	3	0	0	0	1
	3PH Fault w/ Loss of Generator	0	0	0	0	0	0	0
	Loss of Generator (No Fault)	0	0	0	0	0	0	0
P2	3PH Bus Fault	0	0	0	0	0	0	0
P3	Select Cases (Loss of generator with system adjustments) - P1 Analysis	0	0	0	0	0	0	0
P4	SLG Fault with Breaker Failure (Loss of Multiple Elements)	1	0	3	0	1	0	0
P5	3PH Fault w/ Delayed Clearing (Loss of Non-Redundant Component of Protection System)	4	1	4	6	1	0	5



# PSCAD Study Scenarios

## # of PSCAD Simulation Cases – Hawai`i

### Base Case

Planning Event	Description	DP-HD-HW	DP-HD-LW	DP-LD-HW	EP-HD-HW	EP-HD-LW	EP-LD-LW
P1	3PH Fault w/ Loss of Transmission Line (w/ Reclosing)	0	1	0	0	0	0
	3PH Fault w/ Loss of Generator	0	0	0	0	0	0
	Loss of Generator (No Fault)	0	0	0	0	0	0
P2	3PH Bus Fault	0	1	0	0	0	0
P3	Select Cases (Loss of generator with system adjustments) - P1 Analysis	N/A	N/A	N/A	N/A	N/A	N/A
P4	SLG Fault with Breaker Failure (Loss of Multiple Elements)	0	3	2	0	0	0
P5	3PH Fault w/ Delayed Clearing (Loss of Non-Redundant Component of Protection System)	0	6	6	0	0	0



# PSCAD Study Scenarios

## # of PSCAD Simulation Cases – Hawai`i

### Sensitivity Case

Planning Event	Description	DP-HD-HW	DP-HD-LW	DP-LD-HW	EP-HD-HW	EP-HD-LW	EP-LD-LW
P1	3PH Fault w/ Loss of Transmission Line (w/ Reclosing)	N/A	N/A	N/A	N/A	N/A	N/A
	3PH Fault w/ Loss of Generator	N/A	N/A	N/A	N/A	N/A	N/A
	Loss of Generator (No Fault)	N/A	N/A	N/A	N/A	N/A	N/A
P2	3PH Bus Fault	0	1	0	0	0	0
P3	Select Cases (Loss of generator with system adjustments) - P1 Analysis	0	1	0	0	0	0
P4	SLG Fault with Breaker Failure (Loss of Multiple Elements)	0	4	0	0	0	0
P5	3PH Fault w/ Delayed Clearing (Loss of Non-Redundant Component of Protection System)	0	7	0	0	0	0





# O`ahu PSCAD Results Summary

---

- ◆ Most cases are stable, and no UFLS observed.
  - GFM IPP projects response are critical
  - UFLS effectiveness is not reviewed from these PSCAD results.



# PSCAD Results Example – O`ahu P1 Events



# O`ahu PSCAD Results Summary

---

- ◆ DER MC and tripping
  - Whole island DER MC observed in many planning events
  - Large amount of DER tripping observed in P4 and P5 events



# O`ahu PSCAD Results Summary

---

- ◆ Frequency measurement and ROCOF calculation.



# O`ahu PSCAD Results Summary

---

- ◆ IPP project tripping due to AC instantaneous overvoltage
- ◆ Unstable case observed in P5. These unstable cases are known unstable cases from previous studies and have already addressed by fast speed protection.



# Maui Island PSCAD Results Summary

---

- ◆ All cases are stable.
- ◆ No UFLS observed in simulation time window
  - One case will likely have UFLS if simulation time is extended.
  - GFM IPP projects response is critical.



# Maui Island PSCAD Results Summary

---

- ◆ DER MC and tripping
  - Whole island DER MC observed in many planning events
  - Large amount of DER tripping observed in P4 and P5 events
  - Unbalanced tripping of DER causes unbalanced current/power output in synchronous machines and some IPP plants



# Maui Island PSCAD Results Summary

---

## ◆ IPP tripping

- Both existing wind plant and IPP trips after fault being cleared in a few cases.
- Need investigate reason of tripping.

## ◆ IPP oscillation

- Oscillation in wind plant after fault being cleared
- Oscillation from a few IPP projects.





# Hawai`i PSCAD Results Summary

---


- ◆ UFLS – no planning criteria violation due to strong response from GFM projects.
- ◆ Unstable case – Hydro units show instability in a few cases in delayed clearing of 3Ph fault, no system wide instability.
- ◆ System voltage during fault
- ◆ DER MC and Tripping
  - Whole system wide DER MC in a few cases
  - DER trip in delayed clearing fault case
- ◆ ROCOF
  - Well beyond 3Hz/s in many 3Ph fault related cases.



# Synchronous Condenser Sensitivity Study



# Synchronous Condenser Justification



## Note:

1. All these benefits overlap with benefits of firm generation
2. Dynamic var support benefit is locational sensitive.
3. Need consider N-1 scenario




# Next Steps

---

- ◆ DER MC sensitivity study
- ◆ Frequency response resource review sensitivity study
- ◆ Preparing study report.



# Questions for Discussion with TAP



# Questions for Discussion

---

- ◆ Any suggestion/comment for handling frequency measurement modeling in planning study?
  - Current proposal:
    - Putting UFLS relay frequency measurement with high priority than DER frequency measurement
    - Identify DER frequency measurement and ROCOF ride-through via surveying inverter OEM and inverter testing.
- ◆ Any suggestion/comment for synchronous condenser study plan?





Mahalo

Questions?