




**Hawaiian
Electric**

IGP Technical Advisory Panel

March 10, 2022



Agenda

- ◆ Provide overview of Order 38253 issued on March 3, 2022
- ◆ Present a proposed process and assumptions for conducting the probabilistic Resource Adequacy (RA)



Summary of IGP Order 38253

Accepted Items

- Ample opportunities for stakeholder feedback
- Description of purpose/functionality of modeling tools
- Assumptions and models HE used to develop the underlying load forecasts
- Assumptions for each of the five DER forecasts, range of the forecasts, and use for the scenarios and sensitivities
- EV inputs and assumptions
- Fuel price forecasts
- Resource potential using the Alt-1 scenario but agrees that an appropriate cost adder must be included for development on sites with slopes greater than 15%
- Data presentation

Items to be revised to finalize the I&A

- Update Underlying peak forecast for 2017 class load study
- Adjust EE for free-riders, June 2020 C&S, and include all other Achievable Technical Potential in supply curves
- Justify not including a low fuel price forecast in any scenario
- Include a capital cost adder of five cents per watt for utility-scale PV on slopes greater than 15%
- Model a faster customer technology adoption scenario in addition to the high and low load bookends
- Analyze how proposed unit retirement plans affect the optimization of new resources, outside of RPS compliance
- Add comparative statistics and historical data for forecast layers
- Update the IGP webpage for process graphic, model description, meeting recordings, and descriptions of working group pages

Items to be revised in the future

- Include TAP review as part of all review point filings
- Develop alternatives to HDC approach
- Develop different scenarios for underlying load
- Establish a plan to integrate AMI data
- Model EE supply curves in all load sensitivities, include historical program impacts and future C&S within load forecast, and provide clear definitions of free-riders and naturally occurring EE
- Work with stakeholders on how additional resource cost adjustments will be factored into REZ analysis
- Assess the incremental cost and potential for wind and solar projects to be developed on DoD lands
- Evaluate base and high EV adoption with and without managed charging
- Consider economy wide policy and GHG performance in scenario design
- Open access to the modeling tools



Stochastic Assumptions

- ◆ 250 samples – based on a balance of LOLE convergence and reasonable run time (less than a day)
 - 50 outage draws x 5 years of PV and wind patterns (2015 – 2019)
- ◆ Test year would be based on the specific year identified for a future procurement to confirm the reliability need
- ◆ Outage draws are weighted more heavily as part of the sampling because of concerns with continued reliability of the thermal generating fleet as they age through the planning horizon.
 - As variable renewable resources are added through future IGP cycles/procurements, additional weather years can be added and outage draws reduced, with consideration for the test year and any future firm unit additions



Assumptions

- ◆ Thermal Units
 - 50 outage draws
- ◆ PV
 - 5 years of NREL data (2015 - 2019) from Resource Potential study
- ◆ Wind
 - 5 years of historical data (2015 - 2019)
- ◆ Hydro
 - 5 years of historical data (2015 - 2019)
- ◆ Load
 - Future cycles may consider adjustments to the modeled load, either through scenario analysis or correlations developed against historical temperature/humidity



LOLE Benchmark Testing

- ◆ The Company's 2021 calibration factor report will be used to establish an LOLE benchmark that represents the current system.
- ◆ This LOLE benchmark is specifically for testing purposes, to measure against the LOLE resulting from the probabilistic RA conducted on the RESOLVE resource plans per the IGP modeling framework.



Calibration Factor Report

- ◆ The calibration factor is determined by using PLEXOS to simulate the operation of the utility production system for a recorded year, called the “calibration year,” and determining the ratio between the model outputs and recorded amounts for the calibration year.
 - The calibration factor is a constant multiplier used to adjust the fuel consumption determined by a computer production simulation to account for actual operating conditions that are not accurately simulated by the computer model.



Reliability Indices

- ◆ The probabilistic RA will examine the following reliability metrics:
 - LOLE
 - LOLH
 - LOLE_v
 - EUE



Modeling Issues

- ◆ PLEXOS reliability indices are calculated in the LT and MT phase, before the ST hourly simulations. LOLE is manually calculated from simulated hourly data.
 - Can the built in PLEXOS reporting calculate a range of statistics for all the samples from a single test?
 - Should the sample results be summarized at certain percentiles? P90? P80? P50?



O'ahu Renewable Firm RFP

- ◆ Seeks to acquire 500-700 MW of capacity
 - 300-500 MW in service by end of 2029
 - 200 MW in service by end of 2033
- ◆ Assumes existing facilities such as Kalaeloa would need to submit a bid
- ◆ RFP targets were based on capacity needs identified using the August 2021 IGP inputs and assumptions including:
 - Sales forecast
 - Assumptions to no longer dispatch certain existing firm generating units
 - Considerations for developable resource potential from the NREL Alt-1 and Land Constrained scenarios



Next Steps

- ◆ Test the probabilistic resource adequacy for the O'ahu Renewable Firm RFP targets

