


**DRAFT**  
**REQUEST FOR PROPOSALS**  
**FOR**  
**COMMUNITY-BASED RENEWABLE ENERGY**  
**FOR**  
**LOW- AND MODERATE-INCOME SUBSCRIBERS**  
**ISLAND OF MAUI**

AUGUST 21, 2020

Docket No. 2015-0389

*Appendix H – Interconnection Facilities and  
Cost Information*



**Maui  
Electric**

Maui Electric Company  
**APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION**

Tariff Rule No. 19, approved by the PUC, establishes provisions for Interconnection and Transmission Upgrades (see [Appendix I](#)). The tariff provisions are intended to simplify the rules regarding who pays for, installs, owns, and operates interconnection facilities in the context of competitive bidding. Tariff Rule No. 19 will be utilized as the basis for addressing interconnection and transmission upgrades for any projects developed through this RFP. Bidders will comply with the terms and conditions as specified therein.

To assist Bidders in assessing the impacts of location on potential projects, the per unit cost figures provided in the tables below are to be used to provide an approximate estimated cost for interconnecting, including substation, communications, security, and transmission or distribution line cost to the existing Maui Electric System. The per-unit cost figures below should not be used to create a detailed project estimate. A detailed project estimate typically requires a certain level of engineering to assess project site conditions and to factor in other parameters specific to the project.

The Bidder should identify the components assumed for their project and the quantity assumed for each. Each table below provides notes on the assumptions for each of the unit cost estimates. If a Bidder’s project requirements are different than what is assumed in the notes, the Bidder should identify each difference and provide an estimated additional cost or savings resulting from those different requirements.

**2.1 Transmission & Distribution Line Interconnection Costs**

<b>Component</b>	<b>Description</b>	<b>Cost per Mile</b>
1	New 12kV Overhead line (accessible 250' spans)	\$1,020,000
2	12 kV underbuild on existing line (accessible 250' spans)	\$735,000
3	12 kV underbuild on existing line (inaccessible 250' spans)	\$1,292,000
4	New 12kV Underground line	\$1,369,000
5	Padmount service 500 kVA transformer (for station service)	\$89,000
6	PME9 and PME3 switches for 1-ph and 3-ph transformers	\$307,000

**Notes:**

1. Please refer to [Attachment 1](#) (for Projects greater 250 kW and less than 1 MW) or [Attachment 2](#) (for Projects 1 MW or greater) of this [Appendix H](#) for a single line diagram depicting the required interconnection to the Company’s system. Conceptual Design is not intended to cover all interconnection requirements. Final interconnection design will be subject to the results of a technical review.
2. Component 1 assumes wood pole construction.
3. Components 2 and 3 assume no poles need to be replaced.

Maui Electric Company  
APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

4. Component 3 assumes one set of 1000 KCM AL 15kV (600A) cable but does NOT include duct bank and MH construction.
5. Exclusions to these rough costs are as follows but not limited to the following. Proposers should conduct their own due diligence for these costs:
  - a. Development of the PUC application/proceedings timeline
  - b. State or County right-of-way permitting and SMA
  - c. Environmental studies cost
  - d. Survey proposed line extension route
  - e. Easement/Land Issues if discovered in the course of final design
  - f. Archaeological survey and monitoring cost/duration (if needed)
  - g. Clearing/grading along power line corridor and access road
  - h. Final design adjustments required to negotiate terrain, physical landmarks, existing utilities and access
  - i. Construction of permanent roadways/truck access
  - j. Helicopter services
  - k. Traffic Control
  - l. Removals (MECO & HTCOM as applicable)
  - m. Salvage and depreciation credits
  - n. Street lights
  - o. Delays due to weather and material acquisitions
  - p. Civil infrastructure (duct bank, MH, equipment pads, etc.) construction
6. All estimates are provided in 2022 dollars.

The customer shall be responsible to confirm if independent station power is required. Meter requirements should be discussed with Maui Electric during the customer's design stage. Station power shall emanate from an existing 12kV distribution line to the customer's point of connection, either by overhead utility poles or underground line extension. For underground line extensions, the customer shall be responsible for installing and maintaining the infrastructure consisting of, but not limited to, concrete encased ducts, manholes/handholes, transformer and switchgear pads, and meter equipment.

**2.2 Typical CBRE SLD Interconnection Costs (Projects > 250 kW and less than 1 MW)**

Please refer to Attachment 1 of this Appendix H (for Projects greater 250 kW and less than 1 MW). Conceptual Design is not intended to cover all interconnection requirements. Final interconnection design will be subject to the results of the Detailed Evaluation, Technical Review, or an IRS.

Maui Electric Company  
 APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

Component	Description	Cost
1	All other components in Attachment 1 except for the line extension from the project to the utility distribution circuit (See 2.1)	\$313,000

**Notes:**

1. Costs includes components on the Company side of the demarcation shown in Attachment 1.
2. Costs for line extension from the project to tap the distribution circuit should be estimated using 2.1, above.
3. Company shall own a high-speed power quality device (i.e., Tesla Lite Model) near the point of interconnection, which shall be in continuous service and on a rolling window basis monitoring sub-cycle voltages, currents and harmonics, as well as disturbance events and capable of remote interrogation following an event. Company requires 24-hour access to this equipment. Customer to provide the following hard-wired inputs to Company's power quality device:
  - a. Status of Customer's main AC breaker CB-A (MECO# XXXX);
  - b. Line amps (3 phase); and
  - c. Line-to-line voltage (3 phase)
4. Secure and reliable communication is required for the following:
  - a. Revenue metering for power export and consumption readings;
  - b. Phone circuits as required.
5. Customer to design revenue metering facilities in accordance with the requirements in Chapter 4 of the HECO Electric Service Installation Manual.
6. PTs and CTs for high speed digital fault recorder should be the same quality as the PTs and CTs for the protective relaying.
7. Estimate does not contain any of the following costs:
  - a. Telecommunication infrastructure
  - b. Relay Coordination Study
  - c. Land Cost
  - d. Environmental Assessment/Environmental Impact Statement
  - e. Project Management
8. Substation relay protection requirements have not been identified, so costs are based upon typical line protection relaying requirements.

Maui Electric Company  
 APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

**2.3 Typical CBRE SLD Interconnection Costs (Projects 1 MW or greater)**

Please refer to Attachment 2 of this Appendix H (for Projects 1 MW or greater). Conceptual Design is not intended to cover all interconnection requirements. Final interconnection design will be subject to the results of the Detailed Evaluation, Technical Review, or an IRS.

Component	Description	Cost
1	All other components in Attachment 2 at Developer site except for the line extension from the project to the utility distribution circuit (See 2.1)	\$480,000
2	Components at Company Substation including DTT and relaying requirements	\$330,000

**Notes:**

1. Costs includes components on the Company side of the demarcation shown in Attachment 2.
2. Costs for line extension from the project to tap the distribution circuit should be estimated using 2.1, above.
3. Company shall own a high-speed power quality device (i.e., Tesla Model No. 4000) near the point of interconnection, which shall be in continuous service and on a rolling window basis monitoring sub-cycle voltages, currents and harmonics, as well as disturbance events and capable of remote interrogation following an event. Company requires 24-hour access to this equipment. Customer to provide the following hard-wired inputs to Company’s power quality device:
  - a. Status of Customer’s main AC breaker CB-A (MECO# XXXX);
  - b. Status of remotely-resettable lockouts;
  - c. Line amps (3 phase); and
  - d. line-to-line voltage (3 phase)
4. Secure and reliable communication is required for the following:
  - a. Direct transfer trip from \_\_\_\_ (HECO 12kV circuit) 12kV CB \_\_\_\_ (HECO breaker number);
  - b. SCADA to/ from Customer’s facility;
  - c. Revenue metering for power export and consumption readings;
  - d. Power quality and fault recording and retrieval; and
  - e. Phone circuits as required.
5. Customer to provide a reliable DC Source for 12-hour backup period; specific voltage to be determined by Company at a later date.

Maui Electric Company  
APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

6. Upon receipt of direct transfer trip signal from \_\_\_\_\_ (MECO substation name) Substation opening of breaker \_\_\_\_\_ (MECO breaker number), trip and block close Customer's 12 kV breaker CB-A (MECO# XXXX) via Company-owned SCADA resettable lockout relay.
7. Upon DTT communication channel failure longer than 6 seconds:
  - a. Company to provide signal to Customer to initiate Customer performed ramp down and tripping of Customer's 12 kV breaker CB-A (MECO# XXXX).
  - b. Company to initiate trip and block close of Customer's 12 kV breaker CB-A (MECO# XXXX) via Company-owned SCADA resettable lockout relay after \_\_\_\_\_ (Project size MW/2 MW per minute ramp down) minutes.
8. Customer to design revenue metering facilities in accordance with the requirements in Chapter 4 of the HECO Electric Service Installation Manual.
9. PTs and CTs for high speed digital fault recorder should be the same quality as the PTs and CTs for the protective relaying.
10. Component 2 assumes Company Substation is already SCADA enabled.
11. Estimate does not contain any of the following costs:
  - a. Telecommunication infrastructure
  - b. Relay Coordination Study
  - c. Land Cost
  - d. Environmental Assessment/Environmental Impact Statement
  - e. Project Management
12. Substation relay protection requirements have not been identified, so costs are based upon typical line protection relaying requirements.

## **2.4 Telecommunications**

All projects that require telecommunications will require facilities to store the communications equipment. An example for a communications cabinet is provided but other alternatives can be available upon request. The communications equipment will require a communications channel. Some of the communication channel options include microwave, fiber, lease line, or licensed radio. The number of communication circuits (primary/backup) and type of communication circuits required will vary depending on the type/size of the project.

1. Microwave Equipment
  - a. Point-To-Point Microwave: \$684,117 with the following assumptions:
    - i. There is radio line-of-sight clearance between the communication endpoints.
    - ii. FCC licensed Microwave Frequencies are available.
    - iii. There are existing structures/buildings with space available on both ends to house the radio equipment.
    - iv. Telecommunications grounding standards are up-to-date at both sites.
    - v. 48 V DC power with 12 hour battery backup is available.
    - vi. This estimate does not include any special site-specific permit/approval activities that may be required including, but not limited to, Neighborhood

Maui Electric Company  
APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

- Board (s), Conservation District Use Application, Environmental Assessment, Shoreline Management Area approval, biological (endangered species or habitat) surveys, and/or cultural (archeological) surveys or the cost of any migration required for approvals to be granted.
- vii. Space is available at both ends to construct antenna towers or structures that are rated to survive a Saffir-Simpson category 4 hurricane.
  - viii. Cost to interconnect to Hawaiian Electric's existing communications network is not included.
  - ix. Costs are in 2022 dollars.
- b. 50 Foot Microwave Tower: \$591,021 with the following assumptions:
- i. Telecommunications grounding standards are up-to-date.
  - ii. This estimate does not include any special site-specific permit/approval activities that may be required including, but not limited to, Neighborhood Board (s), Conservation District Use Application, Environmental Assessment, Shoreline Management Area approval, biological (endangered species or habitat) surveys, and/or cultural (archeological) surveys or the cost of any migration required for approvals to be granted.
  - iii. Costs are in 2022 dollars.
- c. 100 Foot Microwave Tower: \$858,563 with the following assumptions:
- i. Telecommunications grounding standards are up-to-date.
  - ii. This estimate does not include any special site-specific permit/approval activities that may be required including, but not limited to, Neighborhood Board (s), Conservation District Use Application, Environmental Assessment, Shoreline Management Area approval, biological (endangered species or habitat) surveys, and/or cultural (archeological) surveys or the cost of any migration required for approvals to be granted.
  - iii. Costs are in 2022 dollars.
2. Fiber with overbuild and new construction: \$456,000 per mile with the following assumptions:
- a. Accessible 250' average spans.
  - b. The poles are in good condition and do not need replacing.
  - c. The poles are not overloaded.
  - d. The poles and the attachments are in accordance with NESC 2002 and no work is required to upgrade the poles to current standards.
3. Leased Line: Cost will be the responsibility of the developer and to be negotiated with the lease provider.

Maui Electric Company

APPENDIX H - INTERCONNECTION FACILITIES AND COST INFORMATION

- a. Communication circuit requirements will be based on applications needed for the project.
- b. Company can provide communication circuit interconnection requirements and assist with order review as needed.
4. Communications Cabinet: \$207,365 with the following assumptions:
  - a. Cabinet used to support company equipment and capable of providing communications circuit for SCADA
  - b. Communications cabinet does not include fiber, microwave, or lease circuits.
    - i. Customer to work directly with lease provider if a lease line circuit is needed.
    - ii. Check with company to understand the current lease requirements.
  - c. Customer will provide all conduits, PAD, handholes, AC Power, grounding as required per company standards.
  - d. Cost are in 2022 dollars.
5. Licensed 900 MHz Radio: \$143,626 with the following assumptions:
  - a. This cost will be in addition to the Communication Cabinet cost. The radio equipment will be installed within the Communication Cabinet.
  - b. There is radio line-of-sight clearance between the communication endpoints.
  - c. FCC licensed 900Mhz Frequencies is available.
  - d. There is an existing structure/building with space available on the company side to mount the antenna equipment and house the radio equipment.
  - e. The customer will install a structure to mount the antenna equipment on the customers side.
    - i. Customer will provide any conduit required between the Communications Cabinet and antenna mount structure.
  - f. The cost includes 2 each antenna equipment to create a radio link.
  - g. Cost are in 2022 dollars.

**2.5 Security System Interconnection Costs**

[NOTE: Specific security requirements for the Maui System are under review and will be included in the final RFP.]





